6DU BLDG. 3#5 E.RM.COMB., MISC. DETS.	SCALE
100 UNITS LOW RENT HOUSING PH.A. N.Y. II-2 FOR THE NIAGARA FALLS HOUSING AUTHORITY. NIAGARA FALLS, NEW YORK	AS NOTED
SHACKLETON AND FITZGERALD, A.I.A. ARCHITECTS 1513 LOCKPORT STREET NIAGARA FALLS, N.Y.	JOB NO. 58-147
THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AT SITE BEFORE STARTING WORK	DATE 5-15-60
	DWG. NO. P.206

R. R. FITZGERALD No. 6615
E. R. SHACKLETON No. 6607

REGISTERED ARCHITECTS — UNIVERSITY OF THE STATE OF NEW YORK

I HEREBY CERTIFY THAT THESE PLANS FOR GAS & SANITARY PIPING CONFORM TO THE REQUIREMENTS OF THE PLUMBING CODE OF THE CITY OF NIAGARA FALLS, N.Y. AND ARE CORRECT TO THE BEST OF MY KNOWLEDGE

FOUNDATION PLAN

BASEMENT PLAN

FIRST FLOOR PLAN

SECOND FLOOR PLAN

SCHEMATIC OF GAS METER BAR HOOK UP
NO SCALE

NOTES:
1. CHECK SITE & PLOT PLAN FOR EXACT LOCATION OF G.S., G.A.S. & WATER SERVICE ENTER BACK OF BLDG. WHERE SHOWN ON SITE & PLOT PLAN.
2. COORDINATE WORK WITH HEATING CONTRACTOR & GENERAL CONTR.
ALL LINES TO RUN PARALLEL TO BLDG. LINES, TRUE & PLUMB.

METER BAR — GAS MAIN — CONNECT PIPE TO METER BAR WITH UNIONS & NIPPLES TO FACILITATE INSTALLATION OF CHECK METER.

DETAIL OF WATER & SEWER IN ONE TRENCH
NO SCALE

EXTRA HEAVY C.I. — TOP OF SEWER — 12 MIN — BOTTOM OF WATER MAIN — REGULAR BACKFILL — WELL COMPACTED CLEAN SOIL

SCHEMATIC OF DOMESTIC HOT WATER GENERATOR
(G.U.) COMBINATION 3 4 5 B.R.M
NO SCALE

C.I.W. SUPPLY — H.W. OUTLET — DOMESTIC H.W. GENERATORS 182 CFH TOTAL INPUT 300 BTU/CU.FT. GAS 150 GAL. STORAGE TOTAL 100 % RECOVERY TOTAL — COMBINATION PRESSURE & TEMPERATURE RELIEF VALVE ON BOTH TANKS — FLUE CONNECTION — FLUE THIS CONTRACTOR

DETAIL OF LAUNDRY TUB CONNECTIONS
NO SCALE

LAUNDRY TUB — WINDOW — H.W. — C.W. — STOPS — VENT — PROVIDE CAPPED "T" FOR FUTURE — WATER LINE @ CTG.

SUMP PIT DETAIL
NO SCALE

3" P TRAP. SET BY THIS CONTR. — 3" CONC. @ BOTTOM OF TILE BY G.C. — 6" Ø VT. BY G.C. — SET AG. TILE IN POROUS FILL. AG. TILE BY G.C. — 6" POROUS FILL — 1'-7" MIN. — SLOPE FLOOR TO DRAIN — FURN. & INSTALL BACK WATER CHECK BY THIS CONTR. — ¼" PER. I.R. BY G.C.

DETAIL OF GAS MAIN VENT AT BLDG. ENTRANCE
NO SCALE

PITCH BOTTOM OF PIT AWAY FROM WALL — 2'-0" MIN. — PITCH GAS PIPE AWAY FROM BLDG. — TOP SOIL DOWN TO GRAVEL, ABOUT 1'-0" — PIPE STRAPS SECURED TO BUILDING — COARSE GRAVEL NOT LESS THAN ¾" — FINISH GRADE — 2'-0" MIN. — GRAVEL PIT — 3' — 2' — 18" VENT PIPE COPPER OR COATED FERROUS IN GOOSE NECK TERMINATING PARALLEL WITH BUILDING — GOOSE NECK VENT — WATERPROOF CONNECTION THRU WALL

STACK DIAGRAM #1-35 & #2-35
NO SCALE

BSMT. — 1ST. FLR. — 2ND. FLR. — CLNG. — WATER HAMMER ARRESTORS TOP OF ALL RISERS

STACK DIAGRAM #3-33
NO SCALE

BASEMENT — 1ST. FLR. — 2ND. FLR. — CLNG. — WATER HAMMER ARRESTORS TOP OF ALL RISERS